

**Danfoss A/S**6430 Nordborg
Denmark
CVR nr.: 20 16 57 15Telephone: +45 7488 2222
Fax: +45 7449 0949

UK DECLARATION OF CONFORMITY

Danfoss A/S

Hydronic balancing and control

declares under our sole responsibility that the



Product category: Balancing valves

Type designation(s): AB-QM, ASV-PV, AB-PM, MSV-F2

Covered by this declaration is in conformity with the following directive(s), regulation(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

Pressure Equipment (Safety) Regulations 2016 (as amended)

BS EN 12266-1:2012	Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory requirements
BS EN 12516-2:2014	Industrial valves - Shell design strength - Part 2: Calculation method for steel valve shells
BS EN 13445-3:2021	Unfired pressure vessels - Part 3: Design

Date: 01.03.2023 Place of issue: Ljubljana	Issued by: DocuSigned by:  Matjaž Osojnik <small>B7E670BD3A0B443...</small> Signature: Name: Matjaž Osojnik Title: PPD Director	Date: 01.03.2023 Place of issue: Ljubljana	Approved by DocuSigned by:  Nanna Aage Lundsgaard <small>02742C4F8E8A4FD...</small> Signature: Name: Nanna Aage Lundsgaard Title: Vice President, Head of RD&E
--	--	--	---

Danfoss only vouches for the correctness of the English version of this document. In the event of the document being translated into any other language, the translator concerned must be liable for the correctness of the translation.



Type	DN	PN	PESR Category
AB-QM	65-200	16	I
AB-QM	250	16	II
ASV-PV	65-200	16	I
ASV-PV	250	16	II
AB-PM	65-100	16	I
MSV-F2	65-200	16	I
MSV-F2	250-300	16	II
MSV-F2	350-400	16	III
MSV-F2	50-125	25	I
MSV-F2	150-250	25	II
MSV-F2	300-400	25	III

A risk assessment has been performed and documented according to Schedule 2. Conformity assessment procedure according to Module H - Full quality assurance.

Products in category I,II,III, are marked with UKCA 0041 and evaluated by UK approved body:

Bureau Veritas UK Limited,
2nd Floor,
Atlantic House,
Atlas Business Park,
Manchester,
M22 5PR

Certificate issued: UKCA-0041-PESR-H-DAF 001-22-GBR

Date: 01.03.2023 Place of issue: Ljubljana	Issued by: DocuSigned by: Matjaž Osojnik <small>B7E670BD3A0B443...</small> Signature: Name: Matjaž Osojnik Title: PPD Director	Date: 01.03.2023 Place of issue: Ljubljana	Approved by DocuSigned by: Nanna Aage Lundsgaard <small>02742C4F8E8A4FD...</small> Signature: Name: Nanna Aage Lundsgaard Title: Vice President, Head of RD&E
--	---	--	--

Danfoss only vouches for the correctness of the English version of this document. In the event of the document being translated into any other language, the translator concerned must be liable for the correctness of the translation.